



Presented to:
Energy Save New West

Right-Sizing HVAC Equipment & CSA F280 for Part 9 Buildings

Presented by:
Todd Backus, P.Eng.
December 12th, 2024

AGENDA

1. Introduction
2. Code Requirements
3. CSA F280-12 Standard
4. HLHG Calculation Example
5. 26°C Refuge Room Example
 - When Cooling is Required
6. Right-Sizing HVAC Equipment
 - Ventilation
 - Heat Pumps
7. Q & A



ABOUT TECA

- Non-Profit Trade Association
- Our Mission:
 - Further Education in the HVAC Industry
 - Develop & Provide Training in the HVAC Industry
 - Practical Training for Trades People & Inspectors
 - Advocate for the HVAC Trades to Government
 - Advise Regulators & Building Officials on Best Practices



Heat Loss & Heat Gain Incorporating the CSA F280-12 Calculation Methods

Calculation Methods & Program User Manual



Includes Software & Training

First Edition, April 2018

CODE REQUIREMENTS

- Heating & Cooling Equipment to be sized using CSA F280-12 standard
- Design temperatures are prescriptive
 - Indoor Setpoint Temperatures
 - Outdoor Design Temperatures
- One room must be able to maintain 26°C
 - *Applies to BCBC Only

British Columbia
BUILDING CODE
2024

Book I: General



CODE REQUIREMENTS: CSA F280

9.33.5.1. Capacity of Heating and Cooling Appliances

1) The required capacity of heating and cooling appliances located in a dwelling unit and serving only that dwelling unit, shall be determined in accordance with **CSA F280**, "Determining the required capacity of residential space heating and cooling appliances" except that the design temperatures shall conform to Subsection 9.33.3.



CODE REQ: TEMPERATURES

9.33.3.1. Indoor Design Temperatures

- 1) At the outside winter design temperature, required heating facilities shall be capable of maintaining an indoor air temperature of not less than
 - a) 22°C in all living spaces,
 - b) 18°C in unfinished basements,
 - c) 18°C in common service rooms, ancillary spaces and exits in houses with a secondary suite, &
 - d) 15°C in heated crawl spaces.

CODE REQ: COOLING

9.33.3.1. Indoor Design Temperatures

2) At the outside summer design temperature, required cooling facilities shall be capable of maintaining an indoor air temperature of not more than 26°C in at least one living space in each dwelling unit.

*NOTE: Sentence 9.33.3.1. 2) applies only to the BCBC.



CODE REQ: OUTDOOR TEMP.

9.33.3.2. Outdoor Design Temperatures

- 1) The outdoor conditions to be used in designing heating and air-conditioning systems shall be determined in conformance with Article 1.1.3.1.

1.1.3.1. Climatic and Seismic Values

- 3) The outside winter design temperatures determined from Appendix C shall be those listed for the January 2.5% values.
- 5) The outside summer design temperatures determined from Appendix C shall be those listed for the July 2.5% dry values.

Table C-2
Climatic Design Data for Selected Locations in British Columbia
Forming Part of Appendix C

Province and Location	Elev., m	Design Temperature				Degree-Days Below 18°C	15 Min. Rain, mm	One Day Rain, 1/50, mm	Ann. Rain, mm	Moist. Index	Ann. Tot. Pprn., mm	Driving Rain Wind Pressures, Pa, 1/5	Snow Load, kPa, 1/50		Hourly Wind Pressures, kPa	
		January		July 2.5%									S _s	S _w	1/10	1/50
		2.5% °C	1% °C	Dry °C	Wet °C											
British Columbia																
100 Mile House	1040	-30	-32	29	17	5030	10	48	300	0.4	425	60	2.6	0.3	0.27	0.35
Abbotsford	70	-8	-10	29	20	2880	12	112	1525	1.6	1600	160	2.0	0.3	0.33	0.44
Agassiz	15	-9	-11	31	21	2750	8	128	1650	1.7	1700	160	2.4	0.7	0.35	0.47
Alberni	12	-5	-8	31	19	3100	10	144	1900	2.0	2000	220	2.6	0.4	0.24	0.32
Ashcroft	305	-24	-27	34	20	3700	10	37	250	0.3	300	80	1.7	0.1	0.29	0.38
Bamfield	20	-2	-4	23	17	3080	13	170	2870	3.0	2890	280	1.0	0.4	0.38	0.50
Beaton River	840	-37	-39	26	18	6300	15	64	330	0.5	450	80	3.3	0.1	0.23	0.30
Bella Bella	25	-5	-7	23	18	3180	13	145	2715	2.8	2800	350	2.6	0.8	0.40	0.50
Bella Coola	40	-14	-18	27	19	3580	10	140	1500	1.9	1700	350	4.5	0.8	0.29	0.39
Burns Lake	755	-31	-34	26	17	5450	12	54	300	0.6	450	100	3.4	0.2	0.29	0.39
Cache Creek	455	-24	-27	34	20	3700	10	37	250	0.3	300	80	1.7	0.2	0.29	0.39
Campbell River	20	-5	-7	26	18	3000	10	116	1500	1.6	1600	260	2.8	0.4	0.41	0.48
Carmi	845	-24	-26	31	19	4750	10	64	325	0.4	550	60	3.6	0.2	0.29	0.38
Castlegar	430	-18	-20	32	20	3580	10	54	560	0.6	700	60	4.2	0.1	0.26	0.34
Chetwynd	605	-35	-38	27	18	5500	15	70	400	0.6	625	60	2.4	0.2	0.30	0.40
Chilliwack	10	-9	-11	30	20	2780	8	139	1625	1.7	1700	160	2.2	0.3	0.35	0.47
Colwood Region Colwood (Colwood Corners)	64	-6	-8	26	18	2900	10	100	1000	1.13	1030	220	1.7	0.3	0.48	0.63
Colwood (Royal Bay Village)	20	-5	-7	24	17	2600	8	80	910	1.05	930	220	1.2	0.3	0.48	0.63
Colwood (Triangle Mountain)	220	-7	-9	25	17	3300	10	105	11885	1.29	1225	220	2.5	0.3	0.48	0.63
Comox	15	-7	-9	27	18	2930	10	106	1175	1.3	1200	260	2.4	0.4	0.41	0.48
Courtenay	10	-7	-9	28	18	2930	10	106	1400	1.5	1450	280	2.4	0.4	0.41	0.48
Cranbrook	910	-26	-28	32	18	4400	12	59	275	0.3	400	100	3.0	0.2	0.25	0.33
Crescent Valley	585	-18	-20	31	20	3650	10	54	675	0.8	850	80	4.2	0.1	0.25	0.33
Crofton	5	-4	-6	28	19	2880	8	86	925	1.1	950	160	1.8	0.2	0.32	0.40
Dawson Creek	665	-38	-40	27	18	5900	18	75	325	0.5	475	100	2.5	0.2	0.30	0.40
Dease Lake	800	-37	-40	24	15	6730	10	45	265	0.6	425	50	2.8	0.1	0.23	0.30
Dog Creek	450	-28	-30	29	17	4800	10	48	275	0.4	375	100	1.8	0.2	0.27	0.35
Duncan	10	-6	-8	28	19	2980	8	103	1000	1.1	1050	180	1.9	0.4	0.31	0.39
Elko	1065	-28	-31	30	19	4600	13	64	440	0.5	650	100	3.6	0.2	0.30	0.40
Fernie	1010	-27	-30	30	19	4750	13	118	860	0.9	1175	100	4.5	0.2	0.30	0.40
Fort Nelson	465	-39	-42	28	18	6710	15	70	325	0.6	450	80	2.4	0.1	0.23	0.30
Fort St. John	685	-35	-37	26	18	5750	15	72	320	0.5	475	100	2.8	0.1	0.29	0.39
Glacier	1145	-27	-30	27	17	5800	10	70	625	0.8	1500	80	9.4	0.2	0.24	0.32

CLIMATIC DATA

Appendix C Climatic and Seismic Information for Building Design in Canada

Table C-2
Climatic Design Data for Selected Locations in British Columbia
Forming Part of Appendix C

Province and Location	Elev., m	Design Temperature				Degree-Days Below 18°C	15 Min. Rain, mm	One Day Rain, 1/50, mm	Ann. Rain, mm	Moist. Index	Ann. Tot. Ppn., mm	Driving Rain Wind Pressures, Pa, 1/5	Snow Load, kPa, 1/50		Hourly Wind Pressures, kPa	
		January		July 2.5%									S _s	S _r	1/10	1/50
		2.5% °C	1% °C	Dry °C	Wet °C											
British Columbia																
100 Mile House	1040	-30	-32	29	17	5030	10	48	300	0.4	425	60	2.6	0.3	0.27	0.35
Abbotsford	70	-8	-10	29	20	2860	12	112	1525	1.6	1600	160	2.0	0.3	0.33	0.44
Agassiz	15	-9	-11	31	21	2750	8	128	1650	1.7	1700	160	2.4	0.7	0.35	0.47
Alberni	12	-5	-8	31	19	3100	10	144	1900	2.0	2000	220	2.6	0.4	0.24	0.32
Ashcroft	305	-24	-27	34	20	3700	10	37	250	0.3	300	80	1.7	0.1	0.29	0.38
Bamfield	20	-2	-4	23	17	3080	13	170	2870	3.0	2890	280	1.0	0.4	0.38	0.50



CSA F280-12 (R2021)



Determining the required capacity of residential space heating and cooling appliances



CSA F280 STANDARD

Scope of CSA F280-12 (R2021):

- Calculation method for heat loss & heat gain
- Used for selecting equipment
- Applies to Part 9 Buildings
- **Does not** comment on distribution systems or installation practices
- **Only outputs peak loads!**



F280-12

Determining the required capacity of residential space heating and cooling appliances



CSA F280 STANDARD

- Designed for whole dwelling heating & cooling
- NOT designed to model a single room
 - Assumptions must be made for an accurate model
 - No guidelines available for a refuge room modeling
 - **TECA & HVACDC: Writing refuge room modeling guidelines**





CSA F280 CALCULATORS

F280-12 Software Verified according to the procedure set out in F280-12, Section 8.

COMPANY NAME	SOFTWARE NAME	ROOM BY ROOM	WHOLE HOUSE	CONDITIONS	WEBSITE
Building Technology Services	Building Tech F280			Click Here	BuildingTech
Avenir Software Inc	HeatCAD/LoopCAD			Click Here	HeatCAD LoopCAD
Thermal Environmental Comfort Association	Teca Heat Loss & Heat Gain Calculator			Click Here	
Volta Research Inc	Volta Snap			Click Here	volta SNAP
MiTek Inc	Right-Suite Universal			Click Here	www.wrightsoft.com
Sustainable HVAC Design Inc	Sustainable HVAC F280			Click Here	
McCallum HVAC Design Inc	Mecha F280			Click Here	MCCALLUM HVAC DESIGN INC design excellence with on time delivery

Current List of Certified Calculators: https://hvacdc.ca/?page_id=406



HVAC DESIGNERS OF CANADA
VERIFIED F280 SOFTWARE





CSA F280 REPORTING

CSA Standard F280-12 Report:

- Currently, the results pages are not standardized between different calculators
- A standard report form will be required to simplify the review process

CSA STANDARD F280-12 COMPLIANCE		CSA F280-12 Form Set Ver 24.10	
NBC 2015: 9.33.5.1.; 9.36.3.2. & 9.36.5.15; NBC 2020: 9.33.5.1.; 9.36.3.2.; 9.36.5.15 (5); 9.36.8.9. (1);		PROJECT #	
These documents issued for the use of _____ and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.			
BUILDING LOCATION			
Model: _____	Site: _____		
Address: _____	Lot: _____		
City & Province: _____	Postal Code: _____		
COMPLIANCE (See page 2 for input summary and page 3 for room by room values)			
Submittal is for: <input type="checkbox"/> Whole house <input type="checkbox"/> Room by Room Units: <input type="checkbox"/> Imperial <input type="checkbox"/> Metric			
HEATING			
Minimum Heating Capacity: _____ btuh (total building heat loss as per 5.2.7)			
5.3.1 The total heat output capacity of all heating systems installed in a building shall not be less than 100% of the total building heat loss as determined in Clause 5.2.7.			
5.3.2 The combined heating delivery of the heating systems that serve a room or space shall not be less than 100% of the space heat loss, as determined in Clause 5.2.6. (If room by room submittal, see page 2 for individual space heating requirements)			
COOLING			
Nominal Cooling Capacity: _____ btuh (Nominal Cooling Capacity as per 6.3.1)			
Minimum Cooling Capacity: _____ btuh Maximum Cooling Capacity: _____ btuh			
6.3.2 Except as provided in Clause 6.3.3, the cooling system capacity shall not be less than 80% of the nominal cooling capacity for the building, as determined in Clause 6.3.1. In no case shall it be less than the nominal cooling capacity of the building minus 1800 W (0.51 tons)			
6.3.3 Where the cooling system is added to an existing heating system, its capacity in Watts shall not exceed 18 times the capacity of the air-handling capacity of the existing system in L/s. (Cooling capacity in Tons not more than 1.0 per 400 CFM of air handling capacity)			
6.3.4 Except for ground-source and water source heat pumps used for cooling, and as permitted in Clause 6.3.5, the installed cooling capacity shall not exceed 125% of the nominal cooling capacity for the building, as determined in Clause 6.3.1.			
6.3.5 If the nominal cooling system capacity for the building, as determined in Clause 6.3.1, is less than 6,000 W (1.7 tons), the installed cooling system capacity may exceed the nominal cooling system capacity for the building by up to 1750 W (0.49 tons).			
ATTACHED DOCUMENTS			
<input checked="" type="checkbox"/> Design Summary <input type="checkbox"/> Room by Room Results Other: _____			
Other: _____			
Notes: _____			
CALCULATIONS PERFORMED BY			
Name: _____	Designers Signature, Stamp Imprint or other certification mark	I, _____ have reviewed and take responsibility for the design work described in this document & I am qualified in the appropriate categories.	
Company: _____		Accreditation Reference 1	
Address: _____		Accreditation Reference 2	
City & Prov.: _____		Issued for: _____ (date)	
Postal Code: _____		Issued for: _____ (date)	
Phone: _____			
Fax: _____			
E-mail: _____			
			Page: 1 of
Area for Software vendors information, logo, contact info, version number etc		HVAC DESIGNERS OF CANADA VERIFIED F280 SOFTWARE	

CSA F280 REPORTING

Required Input Information:

- Client & Project Number
- Building Location
- Calculation Assumptions
- Design Temperatures
- Building Envelope Properties
- Contact Information of Designer


Table E.1
Inputs for preparing heat loss and gain calculation summary sheet
 (See Clause 7.1 and Annex D.)

Field	Title	Description	Example
1	Drawings issued for	Client/company the heat loss gain calculations were performed for	John Doe Construction
2	Project number	Client/job code for the use of the issuer of the Heat Loss Gain Calculations	0402-96
BUILDING LOCATION		Where the project is located	
3	Model	Code or name designated to a plan set	Craftsman- Walkout-Option 2
4	Address	Municipal designated location of the project	496 Fake Street
5	City & Province	City (county, township, etc.) and province the project is located in	Toronto, Ontario
6	Site	Name of the development area the project is located in	Fakewood Heights
7	Lot	Numbered land parcel within the site	Lot 16, Phase II
8	Postal Code	Canada Post assigned postal code for the address	M6J 2P9
CALCULATIONS BASED ON		The assumptions and data the heat loss gain calculation is based on	
9	Dimensional information based on	Source of the component sizing data for the heat loss gain calculation	Anybody Design. Dwgs Dated 7/Oct/2010
10	Attachment	Building connection to another building's conditioned space	Detached, left/right/mid, top/bottom/mid
11	Number of stories	Floor levels in the building – Indicate if basement is included	2 + basement
12	Weather location	Weather data location selected in the heat loss gain calculations	Toronto
13	Ventilated?	Was the building's ventilation included in the heat loss gain calculation	Included
14	HRV?	Is an HRV used for the ventilation of the building?	Yes–Blowhard Cyclone 2WA

CSA F280 LIMITATIONS

Calculates Peak Loads:

- Outputs either BTU/hour (or Watts)
 - Energy over **Time**
 - Cannot simulate the build-up of heating over time
 - If the peak load can be satisfied, partial loads will also be satisfied




ABOVE GRADE WALL CALCULATIONS

Components of the Above Grade Wall Calculation:

$$\text{Heat Loss}_{AGW} = \frac{\text{Area}}{R} * \Delta T$$

Where:

- Heat Loss [W or BTUH] = Heat loss requirement at peak load
- Area [m² or ft²] = The area of the wall (adjusted for stud spacing)
- $R \left[\frac{m^2 * ^\circ C}{W} \text{ or } \frac{ft^2 * ^\circ F}{BTUH} \right]$ = Thermal resistance of wall assembly
- ΔT [°C or °F] = Indoor setpoint temperature - Outdoor design temperature



FENESTRATION CALCULATIONS

CSA: 6.2.2. Heat gain through transparent & translucent building assemblies

- Solar Heat Gain Coefficient (SHGC)
- Solar Radiation Incident on the Window (based on orientation & latitude)

$$\text{Heat Gain}_{CT} = \text{Area} * \left\{ \frac{\Delta T}{R} + \text{SHGC} * \text{Solar}_o * \text{Latitude}_{\text{Factor}} \right\}$$

Estimated solar radiation (W/m ²)						
	North	South	East/West	Northeast/ Northwest	Southeast/ Southwest	Horizontal
Solar _o	93	160	285	194	252	534

$$\text{Latitude}_{\text{Factor}} = 1 + \{\text{Latitude} - 40\} * 0.0375$$



INTERNAL LOADS: CSA F280

External Loads:

- Conductive heat transfer, solar radiation, ventilation & leakage

Internal Loads for Heat Gain:

- Occupants: 70 W (240 BTUH) per person
- Electrical:
 - Min. 800 W (2,730 BTUH),
 - 4 W/m² (1.27 BTUH/ft²) if > 200m² (2,150 ft²)



HLHG REPORT: BUILDING INFO

RESULTS

PROJECT #: Example. 453 West 12th Ave. | CSA F280



These results have been generated by The TECA Heat Loss & Heat Gain Calculator (V5.04), which is Verified F280 Software

With the permission of Canadian Standards Association, (operating as "CSA Group"), 178 Rexdale Blvd., Toronto, ON, M9W 1R3, material is reproduced from CSA Group's standard CSA-F280-12 (R2017) Determining the required capacity of residential space heating and cooling appliances. This material is not the complete and official position of CSA Group on the referenced subject, which is represented solely by the Standard in its entirety. While use of the material has been authorized, CSA Group is not responsible for the manner in which the data is presented, nor for any representations and interpretations. No further reproduction is permitted. For more information or to purchase standard(s) from CSA Group, please visit store.csagroup.org or call 1-800-463-6727.

The heating and cooling loads calculated with this calculator tool are the sole responsibility of the user. This tool is to aid the user in applying to the CSA F280-12 calculation methods. The Thermal Environmental Comfort Association of BC accepts no responsibility for damages whatsoever, and offers no guarantee of equipment sizing or configuration.

BUILDING INFORMATION

CALCULATIONS PERFORMED FOR: James Bond

CALCULATIONS PERFORMED BY

NAME: Todd Backus
COMPANY: TECA
ADDRESS: 123 Fake Street
CITY: Nanaimo
PROVINCE: BC
POSTAL CODE: V9R 1P3
PHONE: 555-555-5555
FAX: -
EMAIL: tbackus@teca.ca

SOFTWARE LICENSING

COMPANY: TECA
NAME: Todd Backus
REG. #: 33816800

optional - operator logo, qualification/certification stamp, signature, BCIN qualification attestation, etc.

PROJECT #: Example
ADDRESS: 453 West 12th Ave.
CITY: Vancouver
PROVINCE: BC
POSTAL CODE: V5Y 1V4
BUILDING MODEL:

optional - include photo of house / building drawings here

SITE:
LOT:
DESIGNER OF BUILDING DRAWINGS: JM
DATE OF DRAWINGS: March 21, 2024
BUILDING ATTACHMENT: Detached
NUMBER OF FLOOR LEVELS: 3 NUMBER OF STOREYS: 2 above grade floor levels

PROJECT #: Example. 453 West 12th Ave.

WEATHER DATA: Vancouver (city hall)
LATITUDE: 49.25 LONGITUDE: -123.12
Summer Mean Daily Temperature Range: 7 °C WINDOW SHADING: NO
VENTILATION SYSTEM: Dedicated HRV, 60CFM, ASE0.64, ATRE:0
HEATING SYSTEM: radiant heating (in-floor or baseboards)

FRONT OF HOUSE FACING DIRECTION: SW
is this value assumed? no

AIR TIGHTNESS / INFILTRATION: ACH50: 1, ELA: 96.5 cm², ELA @10Pa
is the air tightness value assumed? yes

BUILDING SITE SHIELDING: Suburban, forest

LOCAL WALL SHIELDING: Open flat terrain, grass

LOCAL FLUE SHIELDING: Open flat terrain, grass

INDOOR DESIGN TEMPERATURES: # OF BEDROOMS: 2
HEATING: 22°C, 71.6°F # OF PEOPLE: 3
COOLING: 24°C, 75.2°F

OUTDOOR DESIGN TEMPERATURES:
HEATING: -7°C, 19.4°F
COOLING: 28°C, 82.4°F

SOIL TEMPERATURE: 11 °C

Attached documents: _____

Assumptions noted (in addition to listed assumptions on page 1): _____

Notes from the calculator operator: _____



HLHG REPORT: BUILDING ASSEMBLY

PROJECT #: Example. 453 West 12th Ave.

BUILDING ENVELOPE ELEMENTS

WALLS

1/ (Wood Wall), Air Film - inside walls, // 1/2" Drywall, // 2*6, 16" OC w/ R6 Insulation, // 2" type 2 bread board as continuous insulation on exterior, // 1/2" Sheeting, // Wall Material - Softwood, air film - outside air; 29.91R-VALUE

CEILINGS

1/ (Ceiling), Air Film - inside ceiling, // 5/8 Drywall, // Ceiling Insulation, // 1/2" Sheathing, // 2" of type 2 insulation, air film - outside air; 57.84R-VALUE

INTERIOR FOUNDATION WALL

EXPOSED FLOOR

1/ (Floor - Exposed), Air Film - inside floors, // Hardwood, // Floor Insulation, // Aluminum Board, air film - outside air; 50.84R-VALUE

EXPOSED HEADER

1/ (Floor Header w/ Wood Walls); 32.3R-VALUE

2/ (Floor Header w/ Leger Board); 35.37R-VALUE

WINDOWS

1/ (Door Window) double glazed, Fixed — Wood/Vinyl, insulating, clear, 6mm Air, USI: 3.13, SHGC: 0.59

2/ (Window - Typ) double glazed, Operable — Wood/Vinyl, insulating, clear, 6mm Air, USI: 2.44, SHGC: 0.49

DOORS

1/ (Door) Insulated metal — Polyurethane core, without storm door, USI: 0.91

FOUNDATIONS

1/ [Basement / Lowest Floor] Concrete Slab & Walls, insulation: interior wall = 2.72RSI, exterior wall = 2.64RSI (configuration #69) // any first storey construction type, interior surface of wall insulated over full-height, exterior surface of wall insulated over full-height, sub-surface of floor slab fully insulated but no insulation under footings, thermal-break between walls and floor slab // AREA: 320ft², FULL PERIMETER: 72ft, EXPOSED PERIMETER: 72ft

WALLS

- 1/ (Wood Wall),
- Air Film - Inside Walls,
- 1/2" Drywall,
- 2*6, 16" OC w/ R6 Insulation,
- 2" Type 2 Bread Board as Continuous Insulation on Exterior,
- 1/2" Sheeting,
- Wall Material - Softwood,
- Air Film - Outside Air;

29.91 R-VALUE



HLHG REPORT: SUMMARY

HEAT LOSS & HEAT GAIN SUMMARY, (BTUH)

imperial



ROOM NAME	FLOOR LEVEL	FL AREA (ft ²)	HEAT LOSS	HEAT GAIN		
			TOTAL	SENS.	TOTAL (sensible + latent)	
(#1)Bath #1	1	84	363	4	5	
(#2)Bed #1	1	180	1935	2346	3050	
(#3)Entrance - Basement	1	80	873	420	546	
(#4)Kitchen & Living	2	344	3655	7178	9332	
(#5)Bath #2	3	40	258	53	69	
(#6)Hall & Laundry	3	89	684	495	644	
(#7)Bed #2	3	215	2596	3592	4669	
			AREA	HEAT LOSS	GAIN (sens.)	GAIN (total)
OVERALL BUILDING			1032	10365	14087	18314



HLHG RESULTS REPORT

Results Output Page:

- Automatically creates a report
- Contains critical design information (per CSA Standard)
- Standardized results page submitted to Building Official (in progress)

CSA STANDARD F280-12 COMPLIANCE		CSA F280-12 Form Set Ver 24.10	
NBC 2015: 9.33.5.1., 9.36.3.2. & 9.36.5.15; NBC 2020: 9.33.5.1.; 9.36.3.2.; 9.36.5.15 (5); 9.36.8.9. (1);		PROJECT #	
These documents issued for the use of <u>Teca</u>		1	
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.			
BUILDING LOCATION			
Model:		Site:	
Address:	152 Nicola St W	Lot:	
City & Province:	Kamloops, BC	Postal Code:	
COMPLIANCE (See page 2 for input summary and page 3 for room by room values)			
Submittal is for:	<input type="checkbox"/> Whole house	<input checked="" type="checkbox"/> Room by Room	Units: <input checked="" type="checkbox"/> Imperial <input type="checkbox"/> Metric
HEATING			
Minimum Heating Capacity:		10,168	BTUH (total building heat loss as per 5.2.7)
5.3.1	The total heat output capacity of all heating systems installed in a building shall not be less than 100% of the total building heat loss as determined in Clause 5.2.7.		
5.3.2	The combined heating delivery of the heating systems that serve a room or space shall not be less than 100% of the space heat loss, as determined in Clause 5.2.6.. (If room by room submittal, see page 2 for individual space heating requirements)		
COOLING			
Nominal Cooling Capacity:		30,577	BTUH (Nominal Cooling Capacity as per 6.3.1)
Minimum Cooling Capacity:		24,462	BTUH
Maximum Cooling Capacity:		38,221	BTUH
6.3.2	Except as provided in Clause 6.3.3., the cooling system capacity shall not be less than 80% of the nominal cooling capacity for the building, as determined in Clause 6.3.1.. In no case shall it be less than the nominal cooling capacity of the building minus 1800 W (0.51 tons)		
6.3.3	Where the cooling system is added to an existing heating system, its capacity in Watts shall not exceed 18 times the capacity of the air-handling capacity of the existing system in L/s. (Cooling capacity in Tons not more than 1.0 per 400 CFM of air handling capacity)		
6.3.4	Except for ground-source and water source heat pumps used for cooling, and as permitted in Clause 6.3.5, the installed cooling capacity shall not exceed 125% of the nominal cooling capacity for the building, as determined in Clause 6.3.1.		
6.3.5	If the nominal cooling system capacity for the building, as determined in Clause 6.3.1. is less than 6,000 W (1.7 tons), the installed cooling system capacity may exceed the nominal cooling system capacity for the building by up to 1750 W (0.49 tons).		
ATTACHED DOCUMENTS			
<input type="checkbox"/> Design Summary	<input checked="" type="checkbox"/> Room by Room Results	Other:	
Notes:			
Assumptions:			
CALCULATIONS PERFORMED BY			
Name:	Andrew Byker	Andrew Byker	
Company:		I have reviewed and take responsibility for the design work described in this document & I am qualified in the appropriate categories. 63	
Address:	7565 Ruby Place	Accreditation Reference 1	
City & Prov.:	Chilliwack, BC	Accreditation Reference 2	
Postal Code:	V2R 3B1	Issued for (date)	
Phone:	604 991 7878	Issued for (date)	
Fax:		Page: 1 of 4	
E-mail:	abyker@teca.ca		
		TECA HEAT LOSS & HEAT GAIN CALCULATOR V5.08 This calculator is CSA F280 verified	
		HVAC DESIGNERS OF CANADA VERIFIED F280 SOFTWARE	



CSA F280 HLHG EXAMPLE

Site Information:

- **Vancouver, BC**
 - **-7°C Winter Design Temperature**
 - **28°C Summer Design Temperature**
- 3 Story, 3,067 ft² detached home
- Indoor setpoint temperature modeled at **26°C for cooling**
 - **CSA F280 specifies indoor setpoint of 24°C for cooling**
- Net Zero building assemblies
- 5 Occupants
- HRV: 110 CFM with 82% ASE
- No window shades included

BASEMENT PLAN


Heat Loss (Heating):

4,477 BTUH

Heat Gain (Cooling):

145 BTUH

*Mostly below grade




MAIN FLOOR PLAN

Heat Loss (Heating):

5,596 BTUH

Heat Gain (Cooling):

9,759 BTUH




TOP FLOOR PLAN

Heat Loss (Heating):

6,042 BTUH

Heat Gain (Cooling):

3,758 BTUH





HEAT LOSS SUMMARY

Vancouver:
Temp. @ -7°C

Heat Loss:
16,115 BTUH

ROOM NAME	WAL.	CEI.	FLR.	WIN.	DR.	FND.	LEAK.	VENT.	DIST.	ADD.	TOTAL
(#18)BASE AREA 1	76			153		1262	803	324			2618
(#18)BASE AREA 2	58					1001	570	230			1859
(#18)FAMILY	542	85		845			242	98			1812
(#18)NOOK	162	10		426			98	40			736
(#18)KITCHEN	56						9	4			69
(#18)POWDER	67						11	4			82
(#18)ENTRY	138			183	334		108	44			807
(#18)LIVING	320			681			165	67			1233
(#18)STAIRS	163	92		204			76	31			565
(#18)DINING	252			445			115	46			857
(#18)W.I.C.	143	45			110		35	14			347
(#18)MASTER BEDROOM	335	272	269	516			162	66			1620
(#18)ENSUITE	55	89	5	255			47	19			471
(#18)BEDROOM2	252	160		653			124	50			1240
(#18)BEDROOM3	212	125		306			75	30			748
(#18)BATH	84	56		89			27	11			267
(#18)LAUNDRY		72	1		64		16	6			159
(#18)BEDROOM4	207	124		204			63	25			623
	<u>WAL.</u>	<u>CEI.</u>	<u>FLR.</u>	<u>WIN.</u>	<u>DR.</u>	<u>FND.</u>	<u>LEAK.</u>	<u>VENT.</u>	<u>DIST.</u>	<u>ADD.</u>	<u>TOTAL</u>
TOTAL BUILDING	3121	1130	275	4960	509	2262	2747	1110			16115



HEAT GAIN SUMMARY

Vancouver:
Temp. @ 28°C

Heat Gain:
13,659 BTUH
***Indoor temp**
@ 26°C

ROOM NAME	WAL.	CEI.	FLR.	WIN.	DR.	LEAK.	VENT.	DIST.	INT.	SENS.	TOTAL
(#18)BASE AREA 1	7			88		2	6			103	133
(#18)BASE AREA 2	9					0	1			10	12
(#18)FAMILY	27	50		706		14	45		1305	2146	2790
(#18)NOOK	8	6		216		4	13			247	321
(#18)KITCHEN									1305	1305	1696
(#18)POWDER											
(#18)ENTRY				122		2	7			132	171
(#18)LIVING	29			715		13	43		1305	2106	2738
(#18)STAIRS	21	54		286		6	21			388	504
(#18)DINING	20			226		4	14		1305	1569	2040
(#18)W.I.C.	8	26				1	2			37	48
(#18)MASTER BEDROOM	26	159		504		12	40			741	964
(#18)ENSUITE		52		225		5	16			298	387
(#18)BEDROOM2	24	94		648		14	44			824	1072
(#18)BEDROOM3	17	73		156		4	14			264	343
(#18)BATH	4	33		45		1	5			89	116
(#18)LAUNDRY		42				1	2			45	59
(#18)BEDROOM4	13	73		104		3	11			204	265
	<u>WAL.</u>	<u>CEI.</u>	<u>FLR.</u>	<u>WIN.</u>	<u>DR.</u>	<u>LEAK.</u>	<u>VENT.</u>	<u>DIST.</u>	<u>INT.</u>	<u>SENS.</u>	<u>TOTAL</u>
TOTAL BUILDING	212	663		4041		88	285		5218	10507	13659

REFUGE ROOM CALCULATIONS


9.33.3.1. Indoor Design Temperatures

2) At the outside summer design temperature, required cooling facilities shall be capable of maintaining an indoor air temperature of not more than 26°C in at least one living space in each dwelling unit.

MODELING A REFUGE ROOM

How to Model (IN MY OPINION):


- Calculate heat gain on the single room (or open area)
- Interior surfaces assumed to be at outdoor design conditions
- Include all dwelling occupants in the refuge room
- Assume a min. electrical load of 800 Watts (2,730 BTUH)
- Indoor setpoint temperature of 26°C
 - CSA F280 Recommends 24°C



SELECTING A REFUGE ROOM

- Must be a finished room
- Consider passive cooling strategies
 - Can some rooms be isolated?
 - Are window shades available?
- Consider occupant comfort
- Review decision after calculation


Is this the best room?



REFUGE ROOM: FAMILY ROOM

Family, Kitchen & Nook as a Refuge Room:


- High occupant comfort level
- Cools a large area
- Excellent selection



REFUGE ROOM: LIVING ROOM

Converting to a Refuge Room:

- Add South & West walls
- Add ceiling
- Add exposed floor
- Add entire ventilation load
- Include all occupants
- Include electrical load





REFUGE ROOM: LIVING ROOM

ROOM NAME	WAL.	CEI.	FLR.	WIN.	DR.	LEAK.	VENT.	DIST.	INT.	SENS.	TOTAL
(#18)BASE AREA 1	7			88		2	6			103	133
(#18)BASE AREA 2	9					0	1			10	12
(#18)FAMILY	27	50		706		14	45		1305	2146	2790
(#18)NOOK	8	6		216		4	13			247	321
(#18)KITCHEN									1305	1305	1696
(#18)POWDER											
(#18)ENTRY				122		2	7			132	171
(#18)LIVING	29			715		13	43		1305	2106	2738
(#18)STAIRS	21	54		286		6	21			388	504
(#18)DINING	20			226		4	14		1305	1569	2040
(#18)W.I.C.	8	26				1	2			37	48
(#18)MASTER BEDROOM	26	159		504		12	40			741	964
(#18)ENSUITE		52		225		5	16			298	387
(#18)BEDROOM2	24	94		648		14	44			824	1072
(#18)BEDROOM3	17	73		156		4	14			264	343
(#18)BATH	4	33		45		1	5			89	116
(#18)LAUNDRY		42				1	2			45	59
(#18)BEDROOM4	13	73		104		3	11			204	265
TOTAL BUILDING	212	663		4041		88	285		5218	10507	13659

Family & Kitchen Heat Gain:
4,807 BTUH

Family & Kit. as Refuge Room:
7,305 BTUH

CSA F280-12
Allows for 80% of total heat gain for min. sizing.
Indoor temperature is 26°C rather than 24°C

	WAL.	CEI.	FLR.	WIN.	DR.	LEAK.	VENT.	DIST.	INT.	SENS.	TOTAL
Family, Nook & Kitchen	61	252		923		35	425		3924	5619	7305

REVIEWING A REFUGE ROOM


Modeling Considerations:

- Is the heat gain calculation performed on the **entire dwelling**, not just the living room?
 - Interior walls and floors will be assumed to have **no heat transfer** because they are modeled as conditioned spaces
- Have the **occupants** been included in the calculation?
- Have the **internal loads** been distributed to multiple rooms?

BASEMENT PLAN

Why not use the basement as a refuge room?


- Internal loads
 - Add 3,924 BTUH
- Occupant comfort
 - Very poor!
- Does this area even require cooling?



COOLING REQUIREMENTS

How do you prove cooling is not required?

- Simulation data must be provided
 - Weather data
 - Building thermal mass
 - Propagation of heat transfer
- Complex analysis!
- Engineer required?



RIGHT SIZING HVAC EQUIPMENT


- Code compliance
- Equipment selection
 - Proper calculations & documentation
- Distribution system sizing
 - Ductwork
 - Radiant
- Verification



DESIGN & PLAN CHECKING


Documents to Submit for Builder Permit:

- Ventilation Checklist
- Heat Loss & Heat Gain Calculation
- Equipment Selection Worksheet
- Design Summary
- System Drawings & Schematics
- Required Permits



9.32 VENTILATION

- Every dwelling requires its own ventilation system
- Ventilation requires exhaust air & outside air
- Minimum airflow rates are prescribed
- Kitchens & bathrooms must have min. ventilation
- Pipe diameters are sized based on airflow & equivalent lengths
- Protection against depressurization (NAFFVA)



VENTILATION REQUIREMENTS

9.32.3.4. Ventilation Systems Supply Air

Outdoor air must be provided to:

- i. **each bedroom**
- ii. **each floor level without a bedroom,**
and
- iii. ancillary spaces that contain an exhaust device, where the space is not within a dwelling unit in a house with a secondary suite and where the house with a secondary suite contains a fuel-fired space-heating appliance or fuel-fired water-heating appliance of other than direct-vented or mechanically vented types,

A-9.32.3.4. Principle Ventilation System Supply Air.




Figure 9.32.3.4.(2)

Forced-Air Heating System Supply Air Distribution

PRINCIPAL EXHAUST FANS

9.32.3.5. Principal Ventilation System Exhaust Fan

- 1) A principal ventilation system exhaust fan shall
 - a) run continuously, and
 - b) provide at least the air-flow rate specified in Table 9.32.3.5.

Floor Area ft ²	Minimum Air-flow Rate, cfm				
	Number of Bedrooms				
	0-1	2-3	4-5	6-7	>7
<1500	30cfm	45cfm	60cfm	75cfm	90cfm
1500-3000	45	60	75	90	105
3001-4500	60	75	90	105	120
4501-6000	75	90	105	120	135
6001-7500	90	105	120	135	150
>7500	105	120	135	150	165

Table 9.32.3.5.
Principal Ventilation System Exhaust Fan Minimum Air-flow Rate
Forming Part of Sentence 9.32.3.5.(1)

Floor Area, m ²	Minimum Air-flow Rate L/s				
	Number of Bedrooms				
	0-1	2-3	4-5	6-7	> 7
< 140	14	21	28	35	42
140-280	21	28	35	42	49
281-420	28	35	42	49	56
421-560	35	42	49	56	64
561-700	42	49	56	64	71
> 700	49	56	64	71	78

VENTILATION REQUIREMENTS

9.32.3.6. Kitchen and Bathroom Exhaust Fans

1) An exhaust fan that provides at least the air-flow rate specified in Table

9.32.3.6. shall be installed in

a) every kitchen, and

b) **every bathroom** or water-closet room, unless the bathroom or water-closet room is served by the principal ventilation system exhaust fan that complies with Article 9.32.3.5.

2) For the purposes of Sentence (1), the capacity rating of the exhaust fan shall be determined, based on air-flow performance at 50 Pa [0.2"wc] of external static pressure, in accordance with...[HVI or CSA standards]

VENTILATION REQUIREMENTS

Table 9.32.3.6
Kitchen/Bathroom Exhaust Fan Minimum Air-flow Rate

Room	Exhaust Rate cfm	
	Intermittent	Continuous
Kitchen	100	N/A
Bathroom	50	20

Note: Minimum Required Rates at 0.2 inches water column external static pressure (ESP).

Table 9.32.3.6.
Kitchen/Bathroom Exhaust Fan Minimum Air-flow Rate
Forming Part of Sentence 9.32.3.6.(1)

Room	Minimum Exhaust Fan Air-flow Rate, L/s	
	Intermittent	Continuous
Kitchen	47	N/A
Bathroom	23	9

VENTILATION REQUIREMENTS

9.32.3.8. Air Ducts

Note: per sentence 7), kitchen ducting to be **non-combustible**



Table 9.32.3.8.
Maximum Equivalent Duct Length ⁽¹⁾, m
Forming Part of Sentence 9.32.3.8.(3)

Flexible Duct						
Equivalent Diameter, mm (Cross Section Area for Rectangular Ducts, cm ²)	Fan Capacity, L/s					
	25	40	50	60	70	80
125 (123)	32	15	-	-	-	-
150 (177)	46	40	28	18	13	-
175 (240)	46	46	46	46	46	24
200 (314)	46	46	46	46	46	46
Rigid Duct						
Equivalent Diameter, mm (Cross Section Area for Rectangular Ducts, cm ²)	Fan Capacity, L/s					
	25	40	50	60	70	80
100 (79)	32	15	-	-	-	-
125 (123)	46	40	28	18	13	-
150 (177)	46	46	46	46	46	24
175 (240)	46	46	46	46	46	46

NAFFVA & DEPRESSURIZATION

9.32.4. Additional Protection Against Depressurization

- Naturally Aspirating Fuel-Fired Vented Appliance (NAFFVA) relies on thermal buoyancy and can cause harm to the occupants if a strong negative pressure reverses the flue gas.




9.33 HEATING & AIR CONDITIONING


- Heating & Cooling Equipment to be sized using CSA F280-12 standard
 - NOTE: Equipment must be sized using design temperatures, **not** nominal values
- Design temperatures are prescriptive
- One room must be able to maintain 26°C



HEAT PUMP BALANCE POINTS



HEAT PUMP BALANCE POINTS





EQUIPMENT SELECTION

1 MHPC Submittal Form

Project Name _____ Date _____ Job # _____
 Job Address _____ City _____ Permit # _____
 Installer _____ Phone _____

1 Load Calculation

Heating Outdoor Design Temperature from CSA F-280 Heat Loss/Heat Gain Calculation (BOX A) °F **A**
 Cooling Outdoor Design Temperature from CSA F-280 Heat Loss/Heat Gain Calculation (BOX B) °F **B**

Total Dwelling Heat Loss in BTUH from CSA F-280 Heat Loss/Heat Gain Calculation (BOX C) BTUH **C**
 Total Dwelling Heat Gain in BTUH from CSA F-280 Heat Loss/Heat Gain Calculation (BOX D) BTUH **D**

2 Heat Emitters Selection

Select Heat Emitter, Heating Supply Water Temperature (BOX E) °F **E**
 Low temp. Convect / Radiator Radiant Floor Low temp. Fan coil Pool/Snowmelt
 Minimum zone load(heating) (BOX F) BTUH **F**

Select Evaporator, Cooling Supply Water Temperature (BOX G) °F **G**
 Suitable Convect Radiant Floor(caution!) Fan coil Minimum zone load(cooling) (BOX H) BTUH **H**

3 Heat Pump Selection Criteria

Use manufacturer specification sheets to select the heat pump and specify Heating and Cooling output (BOX I / J)

Heat Pump Capacity Control
 Single-Stage Multi-Stage Variable speed (Inverter) Monobloc Split

A. Primarily based on the heating load (Heating Only) Yes
 1. Heating output meets the 100% of Total Dwelling Heat Loss (BOX C); Yes
 2. Heating output meets minimum 75% of Total Dwelling Heat Loss (BOX C); Yes Complete section 4

B. Primarily based on the cooling load (Heating and/or Cooling)
 1. Cooling output meets the 100% of the Total Dwelling Heat Gain (BOX D) Yes
 2. Cooling output meets the 100% of Total Dwelling Heat Gain (BOX D) and minimum 75% of the Total Dwelling Heat Loss (BOX C) Yes Complete section 4
 3. Cooling/Heating output meets the 100% of the Total Dwelling Heat Gain/Heat Loss (BOX D/C); Yes

Heating Output BTUH **I**
 BTUH Output @ Heating Design Temperature

Cooling Output BTUH **J**
 BTUH Output @ Cooling Design Temperature

Make _____ Model: _____

2 MHPC Submittal Form

4 Supplementary Heating

Heat Pump Balance Point (BOX K) °F **K**
 Heat Pump Heating Output at Balance Point from manufacturer specification sheets (BOX L) btu/h **L**
 Required Supplementary Heat (BOX M) btu/h **M**
 Heat Pump Heating Output at Balance Point _____ (Box M) minus Total Dwelling Heat Loss at Design Temperature _____ (Box C) = Required Supplementary Heat (Box M)
 Required Supplementary Heat (Box M) is % of Total Dwelling Heat Loss at Design Temperature (Box C)

Supplementary Heating device capacity (BOX N1,N2,N3) meets the Required Supplementary Heat (BOX M): Yes

Gas Boiler btu/h **N1**
 Electric Element kw **N2**
 Electric Boiler kw **N3**

Supplementary Heat Controlled by Heat Pump External Control System

5 Buffer Tank Selection

Buffer Tank Sizing (BOX O1, O2, O3)
 (Use Formula in Appendix for buffer tank sizing.)
 Cooling buffer tank construction and insulation is condensation resistant: Yes

Use Tables 1A, 1B and 1C in Appendix for pipe sizing

Heating gal **O1**
 Cooling gal **O2**
 Heating/cooling gal **O3**

6 Domestic Hot Water

Any Domestic Water Heating: Yes Complete same calculation in section 8 for Domestic Heat Load (BOX P1, P2) btu/h **P1**
A. Preheat with Boost
 Domestic preheat through hydronic buffer tank then boost (thru Tankless Heater) thru Storage Water Heater btu/h **P2**

B. Indirect Fired Heater with Top Up
 1. Priority: Yes No
 2. Top up to 140°F (60°C): Yes
 Heat Pump Gas Boiler Electric Boiler Electric element

7 Heat Pump Circulator

Manufactures minimum required flow rate gpm
 Required flow rate corrected for glycol gpm **Q**
 Total head corrected for glycol ft.hd **R**
 Circulator Sizing
 Heat Pump Flow Requirement (BOX Q & R) in. **S**
 Primary Loop Circulator Sizing (BOX S & T)
 Designed heat pump loop gpm gpm **T**
 Make _____ Model: _____ Speed# _____
 Designed heat pump loop ft. hd. ft.hd **U**

3 MHPC Submittal Form

8 Heat Pump Water Heater

Heat Pump Water Heater

Minimum Domestic Demand: 1st Hour Draw (Box U)
 (Use Table 5 HUD-FHA in Appendix for sizing information)

Chosen Storage Capacity: (Box V)
 (Use Table 5 HUD-FHA in Appendix for sizing information)

1. Selected Storage Capacity _____ (Box V) x 0.6 = Usable Storage (Box X) Gal **V**
 2. 1st Hour Draw Gallons _____ (Box U) minus Usable Storage _____ (Box X) = Shortage Gallons (Box Y) Gal **X**
 3. Shortage Gallons _____ (Box Y) x (8.33 x Temperature Rise _____) = Heat Pump Water Heater Capacity (Box Y) Gal **Y**
 BTUH **Z**

9 System Summary & Schedule

System Summary & Schedule

Pump Schedule				
No.	Model	GPM	Ft.Hd.	

HEAT PUMP:
 Manufacture: _____
 Model: _____
 Designer Name: _____ (Print)
 Designer Signature: _____
 Phone #: _____

TECA Hydronics Design (Heat Pump) Certification #

Heat Pump Guideline Drawing # **AA**

Hydronic Emitter Load Summary			
System	Load (BTUH)	ΔT	Supply Temp (°F)
Low temp. Convect / Radiator			
Radiant Floor			
Low temp. Fan coil			
Pool/Snowmelt			
Domestic			
Other			

Cooling Load Summary			
System	Load (BTUH)	ΔT	Supply Temp (°F)
Fan coil			
Radiant Floor/Ceiling			

Stamp



FORCED AIR DESIGN DOCUMENTS

teca HEAT GAIN Summary & CFM Distribution Worksheet

Q1st # _____ Date _____ Job # _____
 Job Address **BURNABY EXAMPLE**
 Completed by _____ PH _____
 Company _____ Signature _____

STEP 1: Size Appliance on Appliance Selection Worksheet using Minimum Installed System Cooling Capacity from HLHG Results.

STEP 2: Enter Room & Floor in Column 1. Enter Room Cooling Load from the HLHG Results for each room. Add Column 2 to find Base Sensible Cooling and enter in Box 1C.

Column 1 ROOM NAME & FLOOR	Column 2 ROOM HEAT GAIN	Column 3 CFM Dist FACTOR	Column 4 ROOM CFM
Basement A	1	912	49
Basement B	1	839	45
Basement C	1	1123	61
Liv/Entry	2	3033	164
Stairs	2	672	36
Kit/pantry/hall	2	1918	104
Bath	2	342	19
Dine/hall/closet	2	2368	128
Master	3	2244	121
Bed1/hall/closet	3	1497	81
Bed2/hall/closet	3	1027	56
Upper Bath	3	346	19

Cooling CFM Distribution Factor
 Cooling CFM 883 / Box 1C 16321 BTUH = .0541 CFM/BTUH **Box 2C**
 Must be carried to 4 decimal places.

STEP 3: For appliance sized on Appliance Selection Worksheets, use the Cooling CFM divided by Base Sensible Cooling Load (Box 1C).

STEP 4: CFM per Room
 Multiply Column 2 Room Heat Gain by the CFM Distribution Factor to determine the actual CFM required for cooling each room. Record in Column 4.

STEP 5: Compare the heating and cooling CFM. Record the larger of the heating or cooling CFM requirement in Column 5 on the Heat Loss & CFM Summary Worksheet.

Column 4 Note:
 Column 4 Room CFM may be rounded ± 5% for individual run sizing.

Base Sensible Cooling (BTUH)	16321	Box 1C	Total Cooling CFM	883
------------------------------	--------------	--------	-------------------	------------

teca HEAT LOSS Summary & CFM Distribution Worksheet

Q1st # _____ Date _____ Job # _____
 Job Address **BURNABY EXAMPLE**
 Completed by _____ PH _____
 Company _____ Signature _____

STEP 1: Enter Room & Floor in Column 1. Enter Room Heat Loss from HLHG Results sheet in Column 2. Total Column 2 for Base Dwelling Heat Loss (Box 1H).

STEP 2: Enter Ventilation Load from HLHG Results. This is the load for a 4"Ø ventilation air duct or HRV tied into the furnace return air system.

= 3362.4 BTUH **Box 2H**

Note for an HRV with dedicated supply, ventilation air will already be added into each room that was marked with a continuous airflow volume on HLHG Results page.

STEP 3: Total Dwelling Heat Loss for Appliance Selection on Appliance Selection Worksheet:
 Box 1H + Box 2H = 26571.4 BTUH **Box 3H**

STEP 4: Confirm Box 3H is equal to or larger than Minimum Required System Heating Capacity in HLHG Results.

Htg CFM Distribution Factor

STEP 5: For appliance sized on Appliance Selection Worksheets use the larger CFM—either Heating CFM or cooling CFM. Divide by the Base Dwelling Heat Loss (Box 1H).

Larger CFM 883 / Box 1H 23109 BTUH = .0382 CFM/BTUH **Box 4H**
 Must be carried to 4 decimal places.

STEP 6: For Column 4 CFM per Room
 Multiply Column 2 Room Heat Loss by the CFM Distribution Factor to determine

STEP 7: Complete Heat Gain Summary sheet. In Column 5 enter the larger of the heating or cooling CFM requirement for each room. Total Column 5 for the Design CFM that allows for rooms with a larger cooling than heating load.

Column 1 ROOM NAME & FLOOR	Column 2 ROOM HEAT LOSS	Column 3 CFM Dist FACT	Column 4 ROOM Htg CFM AND # DIFFUSERS	Column 5 LARGER OF Htg OR CLG CFM
Basement A	1	3228	123	2 123
Basement B	1	1779	68	1 68
Basement C	1	2410	92	1 92
Living/entry	2	3516	134	2 164
Stairwell	2	1426	54	1 54
Kit/pantry/hall	2	1394	53	1 104
Main Bath	2	324	12	1 19
Dine/hall/closet	2	1650	63	1 128
Master	3	3039	116	2 121
Bed1/hall/closet	3	1787	68	1 81
Bed2/hall/closet	3	1740	66	1 66
Upper Bath	3	816	31	1 31

Base Dwelling Heat Loss (BTUH)	23,109	Box 1H	Total Htg CFM	883	Total Design CFM	1051
--------------------------------	---------------	--------	---------------	------------	------------------	-------------



F.A. SYSTEM DRAWINGS

teca **SUPPLY AIR Worksheet for Conventional System: 0.3"wc ESP**

Q1st # _____ Date _____ Company _____
 Job # _____ Job Address **BURNABY EXAMPLE**
 Completed by _____ Signature _____

Heatloss Method Used: Room-by-Room or Block Load—Flr-by-Flr or Whole House PH

System Sketch		Branch Duct Size		4"Ø			5"Ø			6"Ø			7"Ø		
Show all Trunks & Branch Runs		Max. No. of fittings per branch	4 ftg	6 ftg	7 ftg	4 ftg	6 ftg	7 ftg	4 ftg	6 ftg	7 ftg	4 ftg	6 ftg	7 ftg	
		Max. CFM per branch	35	30	25	65	55	45	100	90	75	160	135	110	
3	Trunk #1	S3 Bedrm 2													66
3		S2 Bedrm 1													81
2		S7 Main Bath													19
1		S14 BSMT C													92
1		S13 BSMT B													68
		Trunk #1 size to Table ST5-6 326 cfm													
2	Trunk #2	S12 Kitchen													104
2		S8 Dining													128
3		S4 Upper Bath													31
3		S1 Stairs													54
3	S6 Master Bedrm													60	
		Trunk #2 size to Table ST5-6 703 cfm													
2	Trunk #3	S11 Living													54
1		S16 BSMT A													63
		Trunk #3 size to Table ST5-6 820 cfm													820
		Trunk #4 to Table ST5-6 231 cfm													231
3	Trunk #4	S5 Master Bedrm													61
2		S10 Living													54
1		S15 BSMT A													60
2		S9 Living													56
		SA Trunk Duct Sizes													
	#1 10 x 8	#4 8 x 8	1051	19		287	85		160	268		232			
	#2 18 x 8	#5	Total CFM	← Add these column totals for Total CFM											
	#3 20 x 8	#6													



Conventional (.3"wc ESP) RETURN AIR System

Heatloss Method Used: Room-by-Room Block Load—Flr-by-Flr or Whole House



JOB #: _____ Address _____
BURNABY EXAMPLE
 Date _____ Completed by _____
 TECA# _____ Signature _____

Show all trunks and branches.

SKETCH	Wall construction	2 x 4	2 x 6	2 x 4	2 x 6	2 x 4	2 x 6
Return Air Grille Size	14 x 6	14 x 8	24 x 6	24 x 8	30 x 6	30 x 8	
Maximum CFM capacity	200	260	350	460	425	580	Always enter actual cfm returned per Column 1
Supply Register Summary per RG	Sub-totals for Trunk Sizing						
upper floor							
RG1							
S1 54							
S2 81							
S3 66							353
S4 31							
S5 61							
S6 60							
353							
#1	Trunk #1 size to RT-2						
main floor							
RG2							
S7 19							
S8 128							
S9 56							
S10 54							
S11 54							
S12 104							
415							
#2	Trunk #2 size to RT-2						
basement							
RG3							
S13 68							
S14 92							
S15 60							
S16 63							
287							
RA Trunk Duct Sizes							
#1 10 x 8	#3 8 x 8	1051		283	353	415	
#2 18 x 8	#4	= Box B	a	b	c	d	e f
Return Air Drop Size	Sized to RT3 24 X 10	a+b+c+d+e+f =	1051	CFM	Box	B	



HYDRONIC SYSTEM DRAWINGS





COMMISSIONING CHECKLIST

HEAT PUMP COMMISSIONING REPORT¹

Customer's Name:		Address:	
Heat Pump Equipment Information			
Manufacturer:		Model#	Outdoor Unit# Indoor Unit#
Heating capacity (BTU/h)		HSPF	
Cooling capacity (BTU/h)		EER (35°C)	
Design air flow (CFM)		SEER	
Variable speed HP compressor	YES / NO	Thermal balance point (°C)	
Duct design static pressure (IWC)			
Existing Heating System Being Replaced	Electric forced air w/out AC Electric forced air w/ AC Electric zonal Air-source heat pump Natural gas furnace Other non-electric heating: _____		
Supplementary/Backup Heating System	Electric forced air w/out AC Electric forced air w/ AC Electric zonal Natural gas furnace Other non-electric heating: _____		
All tests performed in Test Only/Check Charge mode			YES / NO / NA
External Static Pressure Test and Airflow			
Outdoor Air Temperature (°C)			
Test performed in heating or cooling mode?		Heating (if ≤18°C) / Cooling (if >18°C)	
Unit of Pressure Used		Supply Static Pressure	
Return Static Pressure		External Static Pressure	
Compressor suction pressure		Compressor head pressure	
Airflow at Evaporator (CFM)		Measurement method used	Trueflow/ Fan Curve / Temperature split / Other _____

¹ Installation of air-source heat pumps and air conditioners, CSA Standard C273.5-11 and Performance Tested Comfort Systems (PTCS) Air-Source Heat Pump Form

Refrigerant Charge Test			
Heating Mode		Cooling Mode	
Supply Air Temperature (SAT)		Discharge Pressure	
Return Air Temperature (RAT)		Discharge Temperature (DT)	
Temperature Split (SAT – RAT)		Liquid Line Temperature (LLT)	
Expected Temp Split from Performance table		Sub Cooling (DT – LLT)	
Controls			
Is the control system an Integrated Control?		Yes / No	
Control system make and model		Manufacturer: Model:	
Compressor Low Ambient Lockout Control Setting at 3°C or less?		Yes No installed/Disabled Non-electric backup No	
Supplementary/auxiliary heat lockout has been set to:		2°C <2°C	
Power Draw			
Outdoor temperature into Outdoor unit		Outdoor unit power (A)	
Indoor dry bulb temp. into indoor coil		Fan motor power (W)	
Indoor wet bulb temp. into indoor coil		Total unit power (W)	
Temperature of suction line		Temperature of liquid line	
Duct Leakage (applicable for Ducted Systems only)			
Test method used		Duct Blaster / Blow Dorr Subtraction / Other: _____	
Existing system duct leakage (CFM)		Leakage % reduction [(Existing – Post)/Existing]	
Post installation duct leakage (CFM)		Total % leakage (Post/Design)	
Notes:			
The ASHP is designed and installed accordance with CAN/CSA C273.5 and other applicable codes and standards.			
Installer's Signature:		Date:	
Installer's Full Name:		Company Name:	



HOME PERFORMANCE STAKEHOLDER COUNCIL

HPCN HVAC Registration Requires Training:

- HLHG Certification
- Principals of Moving Air
- House as a System (HPSC)



HPCN membership required for many rebates


<https://guides.co/g/updated-home-performance-contractor-network/231461>

TECA COURSES


Quality FIRST

Ventilation Guidelines

A Simplified Guide to Section 9.32-Ventilation of the 2006 British Columbia Building Code




4th Edition, February 2008



Quality FIRST


Heat Recovery Ventilator

Design • Installation
Balancing & Commissioning




With Checklists

Second Edition, February 2019




Quality FIRST

Forced Air Guidelines





Heat Loss & Heat Gain - Appliance Selection
Duct System Layout & Sizing

5th Edition, January 2008




Quality FIRST

Principles of Air





Quality FIRST

Air to Air Heat Pump Guidelines



Produced by the Education Committee of the Thermal Environmental Comfort Association




Quality FIRST

Heat Loss & Heat Gain


Incorporating the CSA F280-12 Calculation Methods

Calculation Methods & Program User Manual




Includes Software & Training

First Edition, April 2018




teca



Hydronic Heat Pump Piping Handbook

Version 1.0 - March 2024



Quality FIRST

Hydronic Systems Design


A Guide To The Design & Installation Of Hot Water Heating Systems





Quality FIRST

Hydronic & Combo Guidelines

for the Design and Installation of Hot Water Heating Systems and Combination Hot Water & Space Heating Systems




Produced by the Education Committee of the Thermal Environmental Comfort Association



Quality FIRST


Hydronics Piping Handbook

Hydronic System Drawings to be used in conjunction with TECA Hydronic & Combo Guidelines, 8th Edition




1st Edition, December 2009

Produced by the Education Committee of the Thermal Environmental Comfort Association




Quality FIRST

HYDRONIC HEAT PUMP DESIGN MANUAL



A Guide To The Design & Installation Hydronic Heat Pump Heating Systems





QUESTIONS & COMMENTS?

Todd Backus, P.Eng.

Manager – Programs Development

cell: 604.838.7511

email: tbackus@teca.ca



END